



Water Board Building  
735 Randolph Street  
Detroit, MI 48226

Customer Care: 313-267-8000  
Emergencies: 313-267-7401  
[detroitmi.gov/dwsd](http://detroitmi.gov/dwsd)

November 29, 2017

Honorable Board of Water Commissioners  
735 Randolph St.  
Detroit, MI 48226

Dear Commissioners:

Re: 7 Mile and Helen, Water Leak

The Detroit Water and Sewerage Department (DWSD) conducted an investigation of a reported water leak at 7 Mile and Helen St. Crews found an 8" gate valve leaking at the stuffing box; the packing and bolts to the stuffing box were replaced. Also, the operating nut was replaced and the gate valve was functioning properly. The repair was completed on November 22, 2017.

Respectfully,

A handwritten signature in black ink that reads "Palencia Mobley". The signature is written in a cursive, flowing style.

Palencia Mobley, P.E.  
Deputy Director and Chief Engineer