



Water Board Building
735 Randolph Street
Detroit, MI 48226

Customer Care: 313-267-8000
Emergencies: 313-267-7401
detroitmi.gov/dwsd

December 5, 2017

James D. Brunell
2806/2810 Rosa Parks
Detroit, MI 48216

Dear Mr. Brunell:

Re: Public Comment – 2806 – 2810 Rosa Parks (Work Order # E219178)

The Detroit Water & Sewerage Department (DWSD) made contact with the customer and issued a ten (10) day notice on or near 11/15/2017. The customer was unsatisfied with DWSD's initial investigation. DWSD crews returned to the site and dug up the stop box and found no leaking on the compression fittings. The crew backfilled and leveled the cold patch, which addressed the customer's asphalt concern. The DWSD crew operated the curb stop and verified that the leak found is on the property owners side of service line (please refer to the attached picture).

The customer is responsible for maintaining repairs on the service line from the curb stop to the home. Therefore, our investigation determined that this is a private plumbing issue located at 2806/2810 Rosa Parks. We encourage you to seek a licensed plumber who will pull the necessary permits with DWSD in order to repair your leak.

Respectfully,

Palencia Mobley, P.E.
Deputy Director and Chief Engineer