



Water Board Building  
735 Randolph Street  
Detroit, MI 48226

Customer Care: 313-267-8000  
Emergencies: 313-267-7401  
[detroitmi.gov/dwsd](http://detroitmi.gov/dwsd)

September 11, 2018

Honorable Board of Water Commissioners  
735 Randolph St.  
Detroit, MI 48226

Dear Commissioners:

Re: 4704 Cass Ave.

Detroit Water & Sewerage Department (DWSD) repaired a leak near 4704 Cass Ave. There was a service leak on the DWSD owned portion of the 1-inch service to the property. DWSD made a temporary repair to stop the leak on August 1, 2018. The business owner requested the final work be completed on a weekend. DWSD replaced the service line from the curb stop to the water main on Sunday, August 12, 2018. The DWSD owned portion of the service line has been replaced.

Respectfully,

A handwritten signature in black ink that reads 'Palencia Mobley'.

Palencia Mobley, P.E.  
Deputy Director and Chief Engineer