



Detroit Water and Sewerage Department

735 Randolph Street
Detroit, Michigan 48226
(313) 224-4704 Office
dwsd.legistar.com

Legislation Details (With Text)

File #: 20-0107 **Version:** 1 **Name:**

Type: Contract **Status:** Passed

In control: Financial Services

On agenda: 4/15/2020 **Final action:** 4/15/2020

Title: The Board of Water Commissioners for the City of Detroit, Water and Sewerage Department authorizes the Director to approve DWSD Contract 6002750 for Project WS-711 with Major Cement Co., for Water System Improvements for various streets in Detroit for a total amount not-to-exceed \$12,978,108.00 and a term of 2 years. This also authorizes the Director to take such other action as may be necessary to accomplish the intent of this vote.

Indexes: Board of Water Commissioners, Finance Committee

Code sections:

Attachments: 1. WS-711 -DWRF A RESOLUTION TO TENTATIVELY AWARD.pdf

Date	Ver.	Action By	Action	Result
4/15/2020	1	Board of Water Commissioners	approved	Pass
4/1/2020	1	Finance Committee	recommended for approval	Pass

The Board of Water Commissioners for the City of Detroit, Water and Sewerage Department authorizes the Director to approve **DWSD Contract 6002750 for Project WS-711 with Major Cement Co., for Water System Improvements for various streets in Detroit for a total amount not-to-exceed \$12,978,108.00 and a term of 2 years.** This also authorizes the Director to take such other action as may be necessary to accomplish the intent of this vote.

Agenda of April 15, 2020

Item No. 20-0107

Contract No. 6002750 / WS-711

Contractor: Major Cement Co. (DBB)

Address: 15347 Dale, Detroit MI 48223

Contract Amount: \$12,978,108.00

Contract Term: 730 Calendar days (2 years) - anticipated start date of 9/1/2020

TO: The Honorable
Board of Water Commissioners
City of Detroit, Michigan

FROM: Gary Brown, Director
Detroit Water and Sewerage Department

RE: Proposed DWSD Contract No. 6002750 - Project No. WS-711
Water System Improvements for various streets in Detroit with
Major Cement Co.

MOTION

Upon recommendation of Mamata Burgi, Procurement Manager, the Board of Water Commissioners for the City of Detroit, Water and Sewerage Department, authorizes the Director to approve **DWSD Contract 6002750 for Project WS-711 with Major Cement Co., for Water System Improvements for various streets in Detroit for a total amount not-to-exceed \$12,978,108.00 and a term of 2 years.** This also authorizes the Director to take such other action as may be necessary to accomplish the intent of this vote.

BACKGROUND / JUSTIFICATION

DWSD Project No. WS-711 is part of an ongoing distribution piping system water main replacement program. The work consists of replacing nearly 41,200 linear feet of existing six through sixteen-inch diameter water mains at selected locations in Detroit that have a history of frequent breaks and high maintenance cost. Lead services forecasted for replacement are 85 and represents 2.2 percent of the contractor's bid. The aggregate forecasted length of Lead services being replaced with copper within the public ROW is 2,326 linear feet and 1,692 linear feet on private properties. Lead services of one inch and less in diameter are replaced with one-inch copper tube; existing lead services of 1.5-inches and 2-inches diameter are replaced with copper tube of the same diameter.

This water main replacement contract is one of a continuing series of contracts that replace the old water mains in the City of Detroit having an extensive history of leaks and breaks. Proposed Project WS-711 will provide the Detroit Water and Sewerage Department (DWSD) with the ability to continue its program of replacing aged water mains that have exceeded their intended service life. The new water mains and associated infrastructure will enhance the integrity of the DWSD Water System and ensure quality service to its customers. To protect the health and safety of our customers, existing Lead water services are being replaced from the new water main all the way to the customer meter.

Proposed Contract 6002750, for Project WS-711, will continue the rehabilitation of water main to provide better services to citizens of Detroit and meet the needs of future City Development.

PROJECT OBJECTIVES / COSTS

The objective of the proposed project WS-711 is to replace existing six through sixteen-inch water mains that have a history of leaks and breaks with approximately 29,518 linear feet of 8-inch, 2,827 linear feet of 12-inch, and 8,845 linear feet of 16-inch ductile iron water main, including fittings, valves, and hydrants. Additionally, existing Lead services will be replaced with copper from the water main to the customer meter. The number of Lead services forecasted for replacement is 85 and it represents 2.2 percent of the contractor's bid. The aggregate forecasted length of Lead services being replaced with copper within the public ROW is 2,326 linear feet and 1,692 linear feet on private properties. Should additional Lead services be encountered over the course

of the work, they shall also be replaced at the rates established in the Bid Schedule.

This is a State of Michigan Drinking Water Revolving Fund (DWRf) project and Federal requirements must be met for Disadvantaged Business Enterprises (DBE), and Davis-Bacon. With regard to DBE participation, prime contractors who bid on a DWRf-funded water main projects and who intend to use subcontractors must demonstrate good-faith procurement outreach efforts for Disadvantaged Business Enterprises (DBE) during the bidding period, which involves soliciting at least three disadvantaged subcontractors per trade, and documenting these efforts in the DBE forms found in the DWRf portion of the bid document specifications. The DBE forms and supporting documents were included in the successful bidder's package in order to comply with DWRf program requirements.

The water main replacement work is broken down as follows:

Street	From	To	New Ductile Iron Water Main (LF)		
			8-inch	12-Inch	16-Inch
Greenfield	West Chicago	Warren Ave	5,240		8,075
NB Southfield Freeway Service Dr.	Seven Mile	Pembroke	2,545		
Greenview	Warren Ave	Paul	2,632		
West Parkway	Tireman	Plymouth	11,566	827	
Jefferson Ave.	Rivard	Orleans	25	1,905	
Jefferson Ave.	Corey	Dickerson	2,353		770
Jefferson Ave.	Mt. Elliott	Beaufait	2,042	95	
Jefferson Ave.	Crane	Pennsylvania	3,115		
		Total:	29,518	2,827	8,845
Project Total Piping:			41,190 Linear Feet		

PROCUREMENT METHOD

This contract was procured through a Request for Bids (RFB) per Requisition 476202 and was advertised on the Michigan Inter-Governmental Trade Network (MITN) website for 29 calendar days. MITN published this opportunity to 1,429 companies and 108 firms downloaded the bid package.

The Engineer's estimate for this work is \$16,085,401.64. The following four (4) bids were received:

Bidder	Total Bid Price	Equalization(s) Applied:	Equalization Credit	Equalized Bid Total:
Major Cement Co.	\$12,978,108.00	DBB 1%	(\$129,781.08)	\$12,848,326.92
Lakeshore Global Corp	\$14,472,252.00	DBB 1%	(\$144,722.52)	\$14,327,529.48
L. D'Agostini & Sons	\$17,051,866.95	N/A	\$0.00	\$17,051,866.95
Ric-Man Construction	\$19,099,613.25	N/A	\$0.00	\$19,099,613.25

Based on the information above, it is recommended that the contract be awarded to the lowest equalized responsive and responsible bidder, Major Cement Co, which is a certified Detroit Based Business.

SUMMARY

A. Contract No.: 6002750

B. Contractor: Major Cement Co.

C. Contract Term: 730 days (2 years) anticipated start date of 9/1/2020

D. Contract Amount: \$12,978,108.00

E. Fiscal Year Breakdown: FY 20-21: \$5,000,000.00
FY 21-22: \$6,000,000.00
FY 22-23: \$1,978,108.00

F. Funding Source: State of Michigan Drinking Water Revolving Fund (DWRf)

G. GL String: 5731-20301-487800-617900-900291-30129-0000-000000 - 100%

This proposed contract was presented to the DWSD Finance Sub Committee on April 1, 2020. Per the DWSD Procurement Policy, this will also be sent for Post FRC review and Detroit City Council approval.